

F. *Outdoor lighting.*

1. Exterior lighting shall be for safety purposes only and shall not be used to attract attention to a business, except as otherwise permitted under the City's sign regulations.
2. Exterior lighting shall be aimed and shielded to prevent glare.
3. Lots abutting residential dwellings shall use low-level lighting and a maximum pole height of 12 feet to minimize light visibility on adjoining properties.
4. Lighting fixtures serving open-air parking lots shall be full cut-off fixtures as defined by the Illuminating Engineering Society of North America (IESNA) in order to direct light downward.
5. Incandescent, fluorescent, color-corrected high-pressure sodium, or metal halide lighting is recommended. The use of solar-powered lighting is encouraged where feasible. Exterior lighting installations should include timers, dimmers, sensors, or photocell controllers that turn the light off during daylight hours or hours when lighting is not needed.